



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVERNMENT OF KARNATAKA UNDERTAKING)

NO:SEE/BEC/EE(O)/AEE/I-125/23-24

Encl:

1167-69

Phone/Fax-080-25423422

Email Id:seeast@bescom.co.in

Office of the  
Superintending Engineer (EI)  
East Circle, BESCOM,  
No.232, 5<sup>th</sup> Main, 3<sup>rd</sup> Cross,  
H.R.B.R Layout, 2<sup>nd</sup> Block,  
Bangalore 560043

Date : 13 MAY 2024

To,

M/s. Coevolve East End Ventures LLP,

Sy.No.77/1A, 77/3, & 77/5,

ECE Road,

Pattandur Agrahara Village,

K.R.Pura(H),

Bengaluru.

Sir,

**Sub:** Issue of NOC for arranging power supply to an extent of 704 kVA in favour of M/s. Coevolve East End Ventures LLP, for proposed Residential building at Sy.No.77/1A, 77/3, & 77/5, ECE Road, Pattandur Agrahara Village, K.R.Pura(H), Bengaluru in E-12 Sub-division-reg.,

**Ref:** Executive Engineer (Ele), Whitefield Division, BESCOM, letter No.: EEE/WFD/AEE(O)/AET/24-25/232 dt.30.04.2024.

\*\*\*\*\*

With reference to the above, 'No Objection Certificate' is issued for arranging LT power supply to an extent of 704 kVA in favour of M/s. Coevolve East End Ventures LLP, Sy.No.77/1A, 77/3, & 77/5, ECE Road, Pattandur Agrahara Village, K.R.Pura(H), Bengaluru in E-12 Sub-division, as per KERC (Recovery of Expenditure for supply of Electricity) Regulations 2004 which is in force and its amendments from time to time subject to the following conditions: Power supply to your Residential building will be arranged with the following arrangements.

## Proposals:-


1. Proposed to tap existing 11kV feeder F12 from "Shantinekethan" MUSS by providing 3 Way DAS RMU (2OD+1VL) at near G.R.Tech Park and extent the 11kV line by laying 3X400 Sq. mm. XLPE UG Cable to a distance of 1.0 km's and terminated inside the proposed project area, by providing 4 Way DAS (2OD+2VL) along with 1X500 kVA+1X250 kVA Transformer and all other accessories on Cement bedding at applicant premises under self-Execution for Regular Source.
2. Alternate power supply shall be arranged from the existing 11KV Feeder F-12 of "EPIP" MUSS at near Nallurahally BESCOM office spun pole duly providing 3 Way DAS RMU (2OD+1VL) at near G.R.Tech Park and extent the 11kV line by laying 3X400 Sq. mm. XLPE UG Cable to a distance of 1.2 km's and terminated up to proposed RMU inside the proposed project area.

You have to develop the above infrastructure including the cost of 11KV lines etc., as mentioned above on self-execution basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

...p.t.o.,

- If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- If any installation existing in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work.
- While applying for power supply to the said **Residential building** at the above address, all rules as per KERC Electricity Supply and Distribution code in force shall be observed.
- Power supply shall be arranged to the said **Residential building** based on the provisions of regulations of BESCOM which are applicable at that time.
- This "NOC" is issued only for the purpose of obtaining sanction plan for **Residential building** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM; Power supply will be sanctioned when applied for, subject to feasibility at that time.
- The approximate load requirement of the above **Residential building** is 704 kVA.
- This NOC is valid for a period of Two year from the date of issue.

Yours faithfully

  
Superintending Engineer (EI)  
Bangalore East Circle.